

FACILITIES STANDARD

NAME : **Plastic Laminate Toilet Partitions**
NUMBER : 10155

ORIGINAL DATE :01-05-98
REVISION DATE :

PURPOSE:

1. The general purpose of each Facilities Standard is to provide minimal criteria for construction materials at University facilities regarding code compliance, warranty, approved products, execution and uniformity.
2. To protect the health and safety of patients, visitors, students, faculty and staff, in addition to protecting non-project UAB property, all construction must be in accordance with: NFPA 241 safeguarding construction, alteration and demolition operations; Standard Building Code, Chapter 33, regarding site work, demolition and construction; NFPA 101 Life Safety Code.
3. Construction safety is the responsibility of the contractor in accordance with the regulations and codes of the agency having jurisdiction, and according to the guidelines adapted by OSHA.
4. The **Plastic Laminate Toilet Partitions Facilities Standard** establishes a series of guidelines for specifying this particular item on any construction project at the University. ***This Facilities Standard is not to be regarded as a specification.***

GENERAL:

1. Toilet Partitions shall be covered in high pressure plastic laminate and shall be in compliance with the following regulatory agencies:
 - A. National Electrical Manufacturers Association (NEMA).
 - B. American National Standards Institute (ANSI)
 - C. Standard Building Code (SBCCI)
 - D. Americans with Disabilities Act (ADA)

NOTE: ADA Guidelines shall be followed for toilet compartment arrangement and hardware installation.

2. Warranty: One (1) year from date of Substantial Completion.

PRODUCTS:

1. High Pressure Plastic Laminate Toilet Partitions shall be equal to:
-
-

- A. Bobrick Washroom Equipment, Inc.
 - B. Ampco Products, Inc.
 - C. Metpar Corp.
 - D. Capitol Partitions, Inc.
2. Toilet Partitions shall be constructed of solid phenolic core material. Construction shall be according to manufacturer's recommendations with stiles and doors a minimum of ¾" thick, and panels and screens a minimum of ½" thick.
 3. The front appearance for Toilet Partitions shall be flush.
 4. The installation method for Toilet Partitions shall be ceiling hung.
 5. If floor mounted installations are necessary because of existing conditions, or to match existing, stile shoes shall be stainless steel.

EXECUTION:

1. Generally, plastic laminate colors shall be neutral, and shall be selected from the manufacturer's standard colors.
2. Generally, hardware shall be chrome plated Zamac.

END OF STANDARD

Prepared by: _____
Evelyn Dauphin

Revised by:

Reviewed and
Recommended by: _____

Approved :

NAME : **Plastic Laminate Toilet Partitions**
NUMBER : 10155

ORIGINAL DATE :01-05-98
REVISION DATE :

Mark A. Goska
Director, Architecture & Engineering

Brooks H. Baker III
Associate Vice President - Facilities